

GOVT OF ASSAM.
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER, P.W.D. JORHAT AND
DERGAON TERRITORIAL BUILDING SUB-DIVISION, JORHAT

No.

Dated-

BUILDING SAFETY CERTIFICATE OF MAHARSHI VIDYA MANDIR, KARANGA, JORHAT

This is to certify that Maharshi Vidya Mandir, Karanga, Jorhat was being inspected by us on 11/02/2022 in the presence of the principal of M.V.M. There are two buildings- i) old building ii) new building. The old building comprises of zero basement and it's a G+2 structure, while the new building comprises of zero basement and it's a G+3 structure

Safety observations found-

- Staircase – Available (1.8M width)- 2nos.-in both buildings.
- Ramp- Available (1.8M width)- 1no.-in the old building.
- Health centre- Available.
- Water supply- Available.
- Sanitation- Separate for both gents & ladies.
- Structural- Safe from visual observations.
- Construction material- RCC construction.

M. D. 15/2/22
Assistant Executive Engineer, P.W.D.
Jorhat and Dergaon, Territorial
Building Sub-Division, Jorhat

Memo no- *ED 30/FE/189/1610-11*

Dated- *15/2/2022*

Copy to-

1. The Executive Engineer, PWD Jorhat District Territorial Building division, Jorhat for favour of your kind information.

✓ 2. The Principal of Maharshi Vidya Mandir, Karanga, Jorhat for information.

M. D. 15/2/22
Assistant Executive Engineer, P.W.D.
Jorhat and Dergaon, Territorial
Building Sub-Division, Jorhat

M. Bardeles
Principal
Maharshi Vidya Mandir
Jorhat

**PROFORMA FOR THE SAFETY OF SCHOOL BUILDING
PART- 1**

(To be filled by the Head of School/ Institute)

- | | | | |
|-----|---|---|---|
| 1. | Name of the School | : | MAHARISHI VIDYA MANDIR, JORHAT |
| 2. | Location | : | JORHAT |
| 3. | Plot Area | : | 7879'66 |
| 4. | Plinth Area | : | |
| 5. | Number of Storey's | : | 1) G+2 2) G+3 |
| 6. | Year of Construction of Building | : | 1) 2007 2) 2016 |
| 7. | If the building has been constructed under the supervision
Of the qualified Engineer, the following details may be given | : | |
| a) | Name of the Engineer with qualification | : | |
| b) | Address of Engineer | : | |
| c) | Set of Structural drawings used in the construction, if available | : | |
| d) | Name & address of Architect with qualification | : | |
| 8. | Whether the building has been constructed for the purpose | : | |
| a) | School | : | YES/ NO <input checked="" type="checkbox"/> |
| b) | Residential Purpose and converted for use as a School | : | YES/ NO |
| 9. | Materials used for roofs | : | |
| a) | R.C.C. Slabs/R.B.C. Slabs | : | RCC slabs YES/ NO <input checked="" type="checkbox"/> |
| b) | R.S. Joist & Battons | : | Rambattons YES/ NO <input checked="" type="checkbox"/> |
| c) | Wooden joists & Battons | : | YES/ NO <input checked="" type="checkbox"/> |
| 10. | Materials used for walls | : | |
| a) | Mud Mortar | : | YES/ NO <input checked="" type="checkbox"/> |
| b) | Cement Mortar | : | Completely cement-mortar YES/ NO <input checked="" type="checkbox"/> |
| c) | Lime Mortar | : | in plastering works. YES/ NO <input checked="" type="checkbox"/> |
| 11. | Flooring | : | |
| a) | Conglomerate | : | Cement conc floors as well as marble flooring YES/ NO <input checked="" type="checkbox"/> |
| b) | Terrazo | : | YES/ NO <input checked="" type="checkbox"/> |
| c) | Brick Paving. | : | YES/ NO <input checked="" type="checkbox"/> |
| 12. | A detailed drawing indicating dimensions of the rooms
Alongwith size and location of doors and windows
(Attached) | : | |

M. Baralaloi
Signature with Stamp of the seal
Of the School/Institution.
Principal
Maharishi Vidya Mandir
Jorhat

PART-II

(To be filled by the S.D.E.)

- a) I have visited the above mentioned school on dated11th February 2022. And have visually inspected it from all angles of safety and find it fit for normal use as School buildings.
- b) In case any addition/ alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by food, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.
- d) This building can be safety occupied for normal use upto (indicate upto which it can be used) on all floors (ie upto 3rd floor in old building and upto 4th floor in new building).

M.D.
15/2/22
Sub Divisional Executive Engineer, P.W.D.
Jorhat & Dergaon. Territorial
Building Sub-Division, Jorhat
Jorhat

M. Boroloi
Principal
Maharishi Vidya Mandir
Jorhat